

Certificate Record

Customer	Class	File Number
BriskHeat Corp 4800 Hilton Corporate Drive, Columbus OH USA 43232	2878-82 HEATERS-Miscellaneous-For Hazardous Locations-Certified to U.S. Standards	116197_0_000

Class I, Division 1, Groups B, C and D

- Fiberglass Heating Jacket, permanently connected, Enclosure rated Type 3, Model series:
HCW-X-Y-Z-1 rated 120Vac, 60Hz, 1-Phase, maximum 150 watts,
HCW-X-Y-Z-2 rated 240Vac, 60Hz, 1-Phase, maximum 150 watts,
for use on metal tanks and vessels
where the "X" in the model designation is a number to denote the diameter in inches, min. 8, max 15
where the "Y" in the model designation is a number to denote the length in inches, min. 15, max. 51
where the "Z" in the model designation is a number to denote the power in watts, 50, 100 or 150 watts max.

Note: Model Series HCW-X-Y-Z is not subject to Re-Ex Testing.

Date: April 12, 2016

Signature:



Full Name:

Douglas R. Dietz

Position:

Vice President of Engineering